

Source of Drinking Water
The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pickup substances resulting from the presence of animals or from human activity.
Contaminants that may be present in source water include:
Microbial contaminants: such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
Inorganic contaminants: such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and spetic systems.
Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.
Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800)426-4791
In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.
Some people may be more vulnerable to contaminants in drinking water than the general population.
Contaminants may be found in drinking water that may cause tase, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the systems business office.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791)			
Violations :			
Violation Period	Analyte	Violation Type:	Violation Explanation
7/10/2024 to 7/11/2024	Consumer Confidence Report	CCR Report	Failed to deliver consumer confidence report to the state or consumers on time
10/6/2024 to 10/15/2024	Consumer Confidence Report	CCR Adequacy/ Availability/ Content	Inadequate CCR or failure to deliver a CCR Certification form to the state on time

EVERTON WATER CORPORATION
 IN5221002
 Annual Water Quality Report for the period of:
 January 1 to December 31, 2024

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.
 The source of drinking water used by EVERTON WAT ER CORPORATION is Ground water
 For more information regarding this report contact:

Name: Tom Fledderman
 Phone: (765) 825-3412

Este informe contiene information muy importante sobre el agua que usted bebe.
 Traduzcalo o hable conb alguien que lo entienda bien.

Water Board meetings are held the first non-Holiday Monday of each month at 6pm. Meetings are held at the Everton Water Office at 5471 S. State Road 1.

EVERTON WATER CORP

2024 Consumer Confidence Report



Everton Water Corporation is pleased to present to you this year's Consumer Confidence Report. The report is designed to inform you about the quality of water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

Source Of Water Information		
Source of Water Name	Type of Water	
Well #1	East	GW
Well #2	West	GW
Well #3	New Well	GW

All wells are located 414 E CO RD 210
 SWA = Source Water Assessment GW=Ground Water

Regulated Contaminants								
Disinfectants And Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorine	2024	1.5	0.3-1.5	MRDLG=4	mrcl=4	ppm	N	Water additive used to control microbes
Haloacetic Acids (HAA5)	2023-2024	7	6.75-6.75	0	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	2023-2024	11	10.9-10.9	0	80	ppb	N	By-product of drinking water disinfection.
Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	4/9/2023	0.071	0.071	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Fluoride	4/9/2023	0.157	0.157	4	4	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate (measured as Nitrogen)	4/9/2023	0.458	0.458	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Lead and Copper	Collection Date	Range of Results	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2021-2024	0.017-0.13	1.3	0.088	0	PPM	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	2021-2024	1.01-1.29	15	1.01	0	PPB	N	Corrosion of household plumbing systems; Erosion of natural deposits.

Lead and Copper

Definitions:
Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. To access Everton Water publicly available lead service line inventory, please use the following link: To access the Everton Water publicly available lead service line inventory please use the following link: <https://pws-ptd.120wateraudit.com/Everton-IN>

Water Quality test results

Definitions:	The following tables contain scientific terms and measures, some of which may require explanation.	AVG:	Regulatory compliance with some MCLS are based on running annual average of monthly samples.
Maximum Contaminant Level Goal or MCLG:	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.	ppm:	milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.
Maximum Contaminant Level or MCL:	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.	ppb:	micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.
Maximum residual disinfectant level goal or MRDLG:	The level of drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.	na:	Not Applicable
Maximum residual disinfectant level or MRDL:	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.	pCi/L:	picocuries per liter (a measure of radioactivity)
Level 1 Assessment:	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.	mrem:	millirems per year (a measure of radiation absorbed by the body)
Level 2 Assessmet:	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.	Treatment Technique or TT:	A required process intended to reduce the level of a contaminant in drinking water.
		LRAA :	Location Running Annual Average

